



Ann Arbor Public Schools  
 Drinking Water Analysis  
 Project Number: AE230030

Pathways to Success									
Date of Sampling: January 5, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Pathways-02	Room 112, Combination Sink, Glass Filler	C	11:17 AM	5	ND <sup>3</sup>	N	Y	7/11/22	Initial First Draw, Filtered.
Pathways-06	Hallway, Outside Room 200, Steel, Glass Filler	G	11:13 AM	5	ND	N	Y	7/11/22	Initial First Draw, Filtered.
Pathways-09	Staff Lounge, 2-Compartment Sink, Bottle Fill	C	11:08 AM	5	ND	N	Y	7/11/22	Initial First Draw, Filtered.
Pathways-15	Multi-Purpose, Refrigerated, Glass Filler	G	11:05 AM	5	ND	N	Y	7/11/22	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L