



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Ann Arbor Open at Mack							
Date of Sampling: 12/21/2019							
Sampler: Kellie Das							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
A2SOM-01	Hallway, Floor 2, Outside Room 209, Hydration Station, Water Cooler	BT	9:02 AM	5	ND ³	N	First Draw, Filtered
A2SOM-02	Room 205, Single Water Cooler	WC	8:58 AM	5	ND	N	First Draw, Filtered
A2SOM-03	Hallway, Floor 2, Left of Dining Room 202, Hydration Station, Water Cooler	BT	8:46 AM	5	ND	N	First Draw, Filtered
A2SOM-04	Hallway, Floor 2, Right of Boiler Room, Hydration Station, Water Cooler	BT	8:19 AM	5	ND	N	First Draw, Filtered
A2SOM-05	Gym Entrance Door, Outside Men's Locker Room, Hydration Station, Water Cooler	BT	8:16 AM	5	ND	N	First Draw, Filtered
A2SOM-06	Kitchen, 3-Compartment Sink, Add On Faucet, Far Left Faucet	KF	8:40 AM	5	ND	Y	First Draw, Filtered
A2SOM-07	OPEN NUMBER						
A2SOM-08	Room 261, Combination Sink, Faucet	C	9:31 AM	5	ND	N	First Draw, Filtered
A2SOM-09	Room 261, Combination Sink, Bubbler	C	9:32 AM	5	ND	N	First Draw, Filtered
A2SOM-10	Hallway, Floor 3, Right of Room 311, Single Water Cooler	WC	11:52 AM	5	ND	N	First Draw, Filtered
A2SOM-11	Room 263, Combination Sink, Faucet	C	9:25 AM	5	ND	Y	First Draw, Filtered
A2SOM-12	Room 315, Kitchen Faucet	KF	11:46 AM	5	ND	Y	First Draw, Filtered
A2SOM-13	Room 306, Kitchen Faucet	KF	11:42 AM	5	ND	Y	First Draw, Filtered

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Ann Arbor Open at Mack

Date of Sampling: 12/21/2019

Sampler: Kellie Das

Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
A2SOM-14	Hallway, Floor 3, Outside Room 302/304, Hydration Station, Water Cooler	BT	11:34 AM	5	ND	N	First Draw, Filtered
A2SOM-15	Hallway, Floor 3, In-between Room 303/305, Hydration Station, Water Cooler	BT	11:30 AM	5	ND	N	First Draw, Filtered
A2SOM-16	Hallway, Floor 3, In-between Room 303/305, Hydration Station, Bottle Fill	BT	11:31 AM	5	ND	N	First Draw, Filtered
A2SOM-17	Room 311, Right Single Sink Faucet	F	11:57 AM	5	ND	Y	First Draw, Filtered
A2SOM-18	Hallway, Floor 1, Outside Room 109B, Hydration Station, Bottle Fill	BT	11:26 AM	5	ND	N	First Draw, Filtered
A2SOM-19	Hallway, Floor 1, Outside Room 109B, Hydration Station, Water Cooler	BT	11:27 AM	5	ND	N	First Draw, Filtered
A2SOM-20	Room 107, Combination Sink, Bubbler	C	11:21 AM	5	3	N	First Draw, Filtered
A2SOM-21	Room 107, Combination Sink, Faucet	C	11:22 AM	5	ND	Y	First Draw, Filtered
A2SOM-22	Room 201, Single Sink Faucet	F	8:52 AM	5	1	N	First Draw, Filtered
A2SOM-23	Staff Lounge, Single Sink Faucet	F	8:36 AM	5	ND	Y	First Draw, Filtered
A2SOM-24	Clinic, Single Sink Faucet	F	9:16 AM	5	6	Y	First Draw, Filtered
A2SOM-25	Main Office, Single Sink Faucet	F	9:15 AM	5	5	Y	First Draw, Filtered
A2SOM-26	OPEN NUMBER						
A2SOM-27	Hallway, Floor 2, Right of Boiler Room, Hydration Station, Bottle Fill	BT	8:18 AM	5	ND	N	First Draw, Filtered

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Ann Arbor Open at Mack							
Date of Sampling: 12/21/2019							
Sampler: Kellie Das							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
A2SOM-28	Hallway, Floor 2, Outside Room 209, Hydration Station, Bottle Fill	BT	9:03 AM	5	ND	N	First Draw, Filtered
A2SOM-29	Room 233/235 Storage Closet, Single Sink Faucet	F	10:56 AM	5	ND	Y	First Draw, Filtered
A2SOM-30	Hallway, Left of Dining Room 202, Hydration Station, Bottle Fill	BT	8:45 AM	5	ND	N	First Draw, Filtered
A2SOM-31	Pool Deck, Single Bubbler	BT	8:10 AM	5	ND	N	First Draw, Filtered
A2SOM-32	Room 233, Combination Sink, Bubbler	C	11:01 AM	5	ND	N	First Draw, Filtered
A2SOM-33	Room 233, Combination Sink, Faucet	C	11:02 AM	5	ND	Y	First Draw, Filtered
A2SOM-34	Room 235, Combination Sink, Bubbler	C	10:52 AM	5	ND	N	First Draw, Filtered
A2SOM-35	Room 235, Combination Sink, Faucet	C	10:53 AM	5	ND	Y	First Draw, Filtered
A2SOM-36	Room 237, Combination Sink, Bubbler	C	10:46 AM	5	ND	N	First Draw, Filtered
A2SOM-37	Room 237, Combination Sink, Faucet	C	10:47 AM	5	ND	Y	First Draw, Filtered
A2SOM-38	Room 239, Combination Sink, Bubbler	C	10:38 AM	5	ND	N	First Draw, Filtered
A2SOM-39	Room 239, Combination Sink, Faucet	C	10:39 AM	5	ND	Y	First Draw, Filtered
A2SOM-40	Room 241, Combination Sink, Bubbler	C	10:32 AM	5	ND	N	First Draw, Filtered
A2SOM-41	Room 241, Combination Sink, Faucet	C	10:33 AM	5	ND	Y	First Draw, Filtered
A2SOM-42	Room 243, Combination Sink, Bubbler	C	10:26 AM	5	ND	N	First Draw, Filtered
A2SOM-43	Room 243, Combination Sink, Faucet	C	10:27 AM	5	ND	N	First Draw, Filtered
A2SOM-44	Room 245, Combination Sink, Bubbler	C	10:20 AM	5	ND	N	First Draw, Filtered

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Ann Arbor Open at Mack							
Date of Sampling: 12/21/2019							
Sampler: Kellie Das							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
A2SOM-45	Room 245, Combination Sink, Faucet	C	10:21 AM	5	ND	Y	First Draw, Filtered
A2SOM-46	Room 247, Combination Sink, Bubbler	C	10:15 AM	5	ND	N	First Draw, Filtered
A2SOM-47	Room 247, Combination Sink, Faucet	C	10:16 AM	5	ND	Y	First Draw, Filtered
A2SOM-48	Room 249, Combination Sink, Bubbler	C	10:10 AM	5	ND	N	First Draw, Filtered
A2SOM-49	Room 249, Combination Sink, Faucet	C	10:11 AM	5	2	N	First Draw, Filtered
A2SOM-50	Room 251, Combination Sink, Bubbler	C	10:05 AM	5	ND	N	First Draw, Filtered
A2SOM-51	Room 251, Combination Sink, Faucet	C	10:06 AM	5	ND	Y	First Draw, Filtered
A2SOM-52	Room 253, Combination Sink, Bubbler	C	9:59 AM	5	ND	N	First Draw, Filtered
A2SOM-53	Room 253, Combination Sink, Faucet	C	10:00 AM	5	ND	Y	First Draw, Filtered
A2SOM-54	Room 255, Combination Sink, Bubbler	C	9:54 AM	5	ND	N	First Draw, Filtered
A2SOM-55	Room 255, Combination Sink, Faucet	C	9:55 AM	5	ND	N	First Draw, Filtered
A2SOM-56	Room 257, Combination Sink, Bubbler	C	9:42 AM	5	ND	N	First Draw, Filtered
A2SOM-57	Room 257, Combination Sink, Faucet	C	9:43 AM	5	3	N	First Draw, Filtered
A2SOM-58	Room 259, Combination Sink, Bubbler	C	9:36 AM	5	ND	N	First Draw, Filtered
A2SOM-59	Room 259, Combination Sink, Faucet	C	9:37 AM	5	ND	Y	First Draw, Filtered
A2SOM-60	Room 261, Combination Sink, Bubbler	C	9:26 AM	5	ND	N	First Draw, Filtered
A2SOM-61	Gym Entrance Door, Outside Men's Locker Room, Hydration Station, Bottle Fill	BT	8:15 AM	5	ND	N	First Draw, Filtered

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030

Ann Arbor Open at Mack							
Date of Sampling: 12/21/2019							
Sampler: Kellie Das							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
A2SOM-62	Hallway, Floor 3, Outside Room 302/304, Hydration Station, Bottle Fill	BT	11:35 AM	5	ND	N	First Draw, Filtered

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Ann Arbor Open at Mack							
Date of Sampling: 1/4/2020							
Sampler: Lindsey Eveleth							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
A2SOM-24A	Clinic, Single Sink, Faucet	F	8:47 AM	5	ND ³	Y	Follow-Up Flush, Filtered.

Ann Arbor Open at Mack							
Date of Sampling: 1/11/2020							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
A2SOM-24B	Clinic, Single Sink, Faucet	F	8:58 AM	5	3	Y	Follow-Up Flush First Draw Following Replacement, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested