



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE240030

Site: Lakewood Elementary School									
Sampling Type: Initial First Draw Sampling (IFD)									
Date of Sampling: February 17, 2024									
Sampler: Teagan Evans									
Sample #	Location	Fixture Type	Time Collected	District Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date	Notes
Lakewood-08	Room 108, Combination Sink, Glass Filler	Combination Sink	8:26 AM	5	ND	N	N	N/A	
Lakewood-14	Room A-6, Combination Sink, Glass Filler	Combination Sink	8:40 AM	5	ND	N	N	N/A	
Lakewood-18	Room A-3, Combination Sink, Glass Filler	Combination Sink	8:45 AM	5	ND	N	N	N/A	
Lakewood-28	Clinic, Combination Sink, Glass Filler	Combination Sink	8:52 AM	5	ND	N	N	N/A	
Lakewood-31	Room 106, Combination Sink, Glass Filler	Combination Sink	8:32 AM	5	ND	N	N	N/A	
Lakewood-35	Hallway, Outside of Gym, Refrigerated Glass Filler	Water Cooler	8:56 AM	5	ND	N	N	N/A	
Lakewood-38	Room D-5, Combination Sink, Glass Filler	Combination Sink	9:01 AM	5	ND	N	N	N/A	
Lakewood-42	Room D-1, Combination Sink, Glass Filler	Combination Sink	9:05 AM	5	ND	N	N	N/A	
Lakewood-51	Cafeteria, Left Wall Glass Filler	Glass Filler	9:10 AM	5	ND	N	N	N/A	

*ND = Non-Detected at Reported Detection Limit of 1 ug/L