



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE230030

Eberwhite Elementary School									
Date of Sampling: January 4, 2023									
Sampler: Victoria Heed									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Eberwhite-03	Room 111, Combination Sink, Glass Filler	C	10:47 AM	5	ND ³	N	Y	6/14/2022	Initial First Draw, Filtered.
Eberwhite-06	Room 125, Combination Sink, Glass Filler	C	10:51 AM	5	ND	N	Y	6/14/2022	Initial First Draw, Filtered.
Eberwhite-08	Hallway, Outside Main Office, Refrigerated Glass Filler	G	10:45 AM	5	ND	N	Y	Unknown Filter Date	Initial First Draw, Filtered.
Eberwhite-16	Gym, Left Wall Glass Filler	G	11:22 AM	5	ND	N	Y	Filter Behind Wall	Initial First Draw, Filtered.
Eberwhite-20	Room 122, Combination Sink, Glass Filler	C	10:55 AM	5	ND	N	Y	6/14/2022	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



**Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE230030**

Eberwhite Elementary School									
Date of Sampling: January 4, 2023									
Sampler: Victoria Heed									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Eberwhite-24	Hallway, Outside Room 126, Hydration Station, Bottle Fill	HS	11:00 AM	5	ND	Y	Y	Green	Initial First Draw, Filtered.
Eberwhite-26	Room 124, Combination Sink, Glass Filler	C	10:57 AM	5	4	N	Y	6/14/2022	Initial First Draw, Filtered.
Eberwhite-27	Room 133, Combination Sink, Glass Filler	C	11:03 AM	5	ND	N	Y	6/15/2022	Initial First Draw, Filtered.
Eberwhite-34	Room 102, Combination Sink, Glass Filler	C	11:08 AM	5	ND	N	Y	6/14/2022	Initial First Draw, Filtered.
Eberwhite-36	Room 110, Combination Sink, Glass Filler	C	11:15 AM	5	ND	N	Y	6/14/2022	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE230030

Eberwhite Elementary School									
Date of Sampling: January 4, 2023									
Sampler: Victoria Heed									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Eberwhite-38	Hallway, Outside Room 106, Hydration Station, Bottle Fill	HS	11:12 AM	5	ND	Y	Y	No Filter Light	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L