



**Ann Arbor Public Schools  
Drinking Water Analysis  
Project Number: AE240030**

Site: Wines Elementary School									
Type of Sampling: Initial First Draw Sampling (IFD)									
Date of Sampling: February 10, 2024									
Sampler: Maryn Burrell									
Sample #	Location	Fixture Type	Time Collected	District Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date	Notes
Wines ES - 01	Room 112, Combination Sink, Glass Filler	Combination Sink	11:40 AM	5	ND	N	Y	6/16/2023	
Wines ES - 05	Room 117, Combination Sink, Glass Filler	Combination Sink	11:50 AM	5	ND	N	Y	6/16/2023	
Wines ES - 06	Room 118, Combination Sink, Glass Filler	Combination Sink	11:45 AM	5	ND	N	Y	6/16/2023	
Wines ES - 10	Portable, Hallway, Refrigerated Glass Filler	Water Cooler	10:45 AM	5	ND	N	N/A	N/A	
Wines ES - 27	Media Center, Combination Sink, Glass Filler	Combination Sink	11:30 AM	5	ND	N	Y	7/19/2022	
Wines ES - 33	Room 110, Combination Sink, Glass Filler	Combination Sink	11:25 AM	5	ND	N	Y	6/16/2023	
Wines ES - 37	Room 109, Combination Sink, Glass Filler	Combination Sink	11:20 AM	5	ND	N	Y	6/16/2023	
Wines ES - 41	Room 106, Combination Sink, Glass Filler	Combination Sink	11:15 AM	5	ND	N	Y	6/16/2023	
Wines ES - 47	Room 103, Combination Sink, Glass Filler	Combination Sink	11:05 AM	5	ND	N	Y	6/16/2023	
Wines ES - 49	Room 102, Combination Sink, Glass Filler	Combination Sink	11:10 AM	5	ND	N	Y	6/16/2023	
Wines ES - 64	Hallway, Outside Gym, Hydration Station, Bottle Fill	Hydration Station	11:35 AM	5	ND	Y	N/A	N/A	
Wines ES - 51	Room 100, Right Glass Fill	Combination Sink	10:55 AM	5	ND	N	Y	6/16/2023	

\*ND = Non-Detected at Reported Detection Limit of 1 ug/L