



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Logan Elementary School							
Date of Sampling: 1/25/2020							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Logan ES-01	Hallway, Outside Room 262, Hydration Station, Water Cooler	BT	8:35 AM	5	ND ³	N	First Draw, Filtered.
Logan ES-02	Teacher's Lounge, Single Sink, Faucet	F	8:48 AM	5	ND	Y	First Draw, Filtered.
Logan ES-03	Gym, Kitchen, Two-Compartment Sink	KF	8:30 AM	5	ND	Y	First Draw, Filtered.
Logan ES-04	Hallway, Outside of Room C-256, Hydration Station, Bottle Fill	BT	9:00 AM	5	ND	N	First Draw, Filtered.
Logan ES-07	Room 324, Combination Sink, Bubbler	C	8:15 AM	5	ND	N	First Draw, Filtered.
Logan ES-13	Room 324, Combination Sink, Faucet	C	8:16 AM	5	2	Y	First Draw, Filtered.
Logan ES-49	Kitchen, Three-Compartment Sink, Add On Far Right Faucet	KF	8:10 AM	5	ND	Y	First Draw, Filtered.
Logan ES-52	Hallway, Outside Room C-256, Hydration Station, Water Cooler	BT	9:00 AM	5	ND	N	First Draw, Filtered.
Logan ES-53	Hallway, Outside of Room C-262, Hydration Station, Bottle Fill	BT	8:40 AM	5	ND	N	First Draw, Filtered.
Logan ES-54	Multi-Use/Cafeteria, Small Entry Hallway, Outside Kitchen Door, Single Water Cooler	WC	8:22 AM	5	ND	N	First Draw, Filtered.
Logan ES-55	Multi-Use/Cafeteria, Small Entry Hallway, Outside Kitchen Door, Hydration Station, Bottle Fill	BT	8:24 AM	5	ND	N	First Draw, Filtered.
Logan ES-56	Multi-Use/Cafeteria, Small Entry Hallway, Outside Kitchen Door, Hydration Station, Water Cooler	BT	8:25 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Logan Elementary School							
Date of Sampling: 3/7/2020							
Sampler: Lindsey Eveleth							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Logan ES-05	Media Center, Right of East Teacher's Work Room, Outside Room C-233, Hydration Station, Water Cooler	BT	7:10 AM	5	ND	N	First Draw, Filtered.
Logan ES-06	Media Center, Right of East Teacher's Work Room, Outside Room C-233, Single Water Cooler	WC	7:12 AM	5	ND	N	First Draw, Filtered.
Logan ES-08	Media Center, Right of West Teacher's Work Room, Outside Room C-324, Hydration Station, Water Cooler	BT	6:53 AM	5	ND	N	First Draw, Filtered.
Logan ES-09	Media Center, Right of West Teacher's Work Room, Outside Room C-324, Single Water Cooler	WC	6:55 AM	5	ND	N	First Draw, Filtered.
Logan ES-10	Room 240, Combination Sink, Bubbler	C	7:39 AM	5	ND	N	First Draw, Filtered.
Logan ES-11	Room 234, Combination Sink, Faucet	C	7:50 AM	5	ND	Y	First Draw, Filtered.
Logan ES-12	Room 220, Combination Sink, Bubbler	C	8:01 AM	5	ND	N	First Draw, Filtered.
Logan ES-14	Room 326, Combination Sink, Bubbler	C	6:48 AM	5	ND	N	First Draw, Filtered.
Logan ES-15	Room 326, Combination Sink, Faucet	C	6:50 AM	5	ND	Y	First Draw, Filtered.
Logan ES-16	Room 328, Combination Sink, Bubbler	C	6:44 AM	5	ND	N	First Draw, Filtered.
Logan ES-17	Room 328, Combination Sink, Faucet	C	6:46 AM	5	ND	Y	First Draw, Filtered.
Logan ES-18	Room 330, Combination Sink, Bubbler	C	6:40 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Logan Elementary School							
Date of Sampling: 3/7/2020							
Sampler: Lindsey Eveleth							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Logan ES-19	Room 330, Combination Sink, Faucet	C	6:42 AM	5	ND	Y	First Draw, Filtered.
Logan ES-20	Room 332, Combination Sink, Bubbler	C	6:35 AM	5	ND	N	First Draw, Filtered.
Logan ES-21	Room 332, Combination Sink, Faucet	C	6:37 AM	5	ND	Y	First Draw, Filtered.
Logan ES-22	Room 333, Combination Sink, Bubbler	C	6:30 AM	5	ND	N	First Draw, Filtered.
Logan ES-23	Room 333, Combination Sink, Faucet	C	6:32 AM	5	ND	Y	First Draw, Filtered.
Logan ES-24	Room 335, Combination Sink, Bubbler	C	6:19 AM	5	ND	N	First Draw, Filtered.
Logan ES-25	Room 335, Combination Sink, Faucet	C	6:20 AM	5	ND	N	First Draw, Filtered.
Logan ES-26	Room 212, Combination Sink, Bubbler	C	8:05 AM	5	ND	N	First Draw, Filtered.
Logan ES-27	Room 212, Combination Sink, Faucet	C	8:06 AM	5	1	Y	First Draw, Filtered.
Logan ES-28	Room 220, Combination Sink, Faucet	C	8:00 AM	5	ND	Y	First Draw, Filtered.
Logan ES-29	Room 224, Combination Sink, Bubbler	C	7:57 AM	5	ND	N	First Draw, Filtered.
Logan ES-30	Room 224, Combination Sink, Faucet	C	7:59 AM	5	1	Y	First Draw, Filtered.
Logan ES-31	Room 230, Combination Sink, Bubbler	C	7:55 AM	5	ND	N	First Draw, Filtered.
Logan ES-32	Room 230, Combination Sink, Faucet	C	7:56 AM	5	2	Y	First Draw, Filtered.
Logan ES-33	Room 233, Combination Sink, Bubbler	C	7:53 AM	5	ND	N	First Draw, Filtered.
Logan ES-34	Room 233, Combination Sink, Faucet	C	7:54 AM	5	4	Y	First Draw, Filtered.
Logan ES-35	Room 234, Combination Sink, Bubbler	C	7:51 AM	5	ND	N	First Draw, Filtered.
Logan ES-36	Room 236, Combination Sink, Bubbler	C	7:48 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Logan Elementary School							
Date of Sampling: 3/7/2020							
Sampler: Lindsey Eveleth							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Logan ES-37	Room 236, Combination Sink, Faucet	C	7:49 AM	5	2	Y	First Draw, Filtered.
Logan ES-38	Room 238, Combination Sink, Bubbler	C	7:43 AM	5	ND	N	First Draw, Filtered.
Logan ES-39	Room 238, Combination Sink, Faucet	C	7:44 AM	5	2	Y	First Draw, Filtered.
Logan ES-40	Room 240, Combination Sink, Faucet	C	7:41 AM	5	1	Y	First Draw, Filtered.
Logan ES-41	Room 241, Combination Sink, Bubbler	C	7:19 AM	5	ND	N	First Draw, Filtered.
Logan ES-42	Room 241, Combination Sink, Faucet	C	7:21 AM	5	ND	Y	First Draw, Filtered.
Logan ES-43	Room 243, Combination Sink, Bubbler	C	7:15 AM	5	ND	N	First Draw, Filtered.
Logan ES-44	Room 243, Combination Sink, Faucet	C	7:17 AM	5	4	Y	First Draw, Filtered.
Logan ES-45	Room 250, Combination Sink, Bubbler	C	7:05 AM	5	ND	N	First Draw, Filtered.
Logan ES-46	Room 250, Combination Sink, Faucet	C	7:07 AM	5	2	Y	First Draw, Filtered.
Logan ES-47	Room 253, Combination Sink, Bubbler	C	7:00 AM	5	ND	N	First Draw, Filtered.
Logan ES-48	Room 253, Combination Sink, Faucet	C	7:02 AM	5	ND	Y	First Draw, Filtered.
Logan ES-51	Media Center, Right of West Teacher's Work Room, Outside Room C-324, Hydration Station, Bottle Fill	BT	6:54 AM	5	ND	N	First Draw, Filtered.
Logan ES-57	Media Center, Right of East Teacher's Work Room, Outside Room C-234, Hydration Station, Water Cooler	BT	7:11 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested