



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Lakewood Elementary School							
Date of Sampling: 10/27/18							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lakewood-41	Room D-6, Faucet	C	4:19 PM	5	7	Y	First Draw

Lakewood Elementary School							
Date of Sampling: 12/22/18							
Sampler: Jenna Sendra							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lakewood-41	Room D-6, Faucet	C	9:36 AM	5	3	Y	Follow-Up First Draw Following Replacement

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminante>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested