



Ann Arbor Public Schools  
 Drinking Water Analysis  
 Project Number: AE230030

Westerman Preschool									
Date of Sampling: January 6, 2023									
Sampler: Sabrina Fouche and Victoria Heed									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
PFC-01	Hallway Outside Room B112, Refrigerated Glass Filler	G	6:50 AM	5	ND <sup>3</sup>	N	Y	Unknown	Initial First Draw, Filtered.
PFC-02	Room A102, Combination Sink, Glass Filler	C	7:24 AM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.
PFC-03	Room A100, Combination Sink, Glass Filler	C	7:38 AM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.
PFC-04	Room B102, Combination Sink, Glass Filler	C	7:58 AM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.
PFC-05	Room B105, Combination Sink, Glass Filler	C	8:04 AM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.
PFC-06	Lobby, Outside Room E100, Combination Sink, Glass Filler	C	8:23 AM	5	ND	N	Y	7/12/2022	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
 Drinking Water Analysis  
 Project Number: AE230030

Westerman Preschool									
Date of Sampling: January 6, 2023									
Sampler: Sabrina Fouche and Victoria Heed									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
PFC-07	Room A108, Combination Sink, Glass Filler	C	7:00 AM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.
PFC-10	Room D100, Combination Sink, Glass Filler	C	6:39 AM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.
PFC-12	Room D102, Combination Sink, Glass Filler	C	6:53 AM	5	ND	N	N	N/A	Initial First Draw, Filter In Progress.
PFC-13	Kitchen, 3-Compartment Sink, Middle Faucet, Kitchen Faucet	KF	7:42 AM	5	ND	Y	Y	7/12/2022	Initial First Draw, Filtered.
PFC-15	Hallway Outside Room D109, Hydration Station, Bottle Fill	HS	7:34 AM	5	ND	Y	Y	No Filter Light	Initial First Draw, Filtered.
PFC-17	Room C105, Combination Sink, Glass Filler	C	7:48 AM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
 Drinking Water Analysis  
 Project Number: AE230030

Westerman Preschool									
Date of Sampling: January 6, 2023									
Sampler: Sabrina Fouche and Victoria Heed									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
PFC-23	Room C102, Combination Sink, Glass Filler	C	8:06 AM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.
PFC-27	Room C112, Combination Sink, Glass Filler	C	7:37 AM	5	ND	N	Y	6/16/2020	Initial First Draw, Filtered.
PFC-34	Room D103, Combination Sink, Glass Filler	C	7:22 AM	5	ND	N	N	N/A	Initial First Draw, Filter In Progress.
PFC-39	Room E105, Combination Sink, Glass Filler	C	8:26 AM	5	ND	N	Y	4/20/2021	Initial First Draw, Filtered.
PFC-43	Room B100, Combination Sink, Glass Filler	C	7:43 AM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.
PFC-48	Room B103, Combination Sink, Glass Filler	C	8:02 AM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
 Drinking Water Analysis  
 Project Number: AE230030

Westerman Preschool									
Date of Sampling: January 6, 2023									
Sampler: Sabrina Fouche and Victoria Heed									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
PFC-53	Room A105, Combination Sink, Glass Filler	C	7:04 AM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.
PFC-57	Room A103, Combination Sink, Glass Filler	C	7:21 AM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.
PFC-65	Hallway Outside Room B112, Hydration Station, Bottle Fill	HS	6:51 AM	5	ND	Y	Y	Green	Initial First Draw, Filtered.
PFC-68	Room E100, Hydration Station, Bottle Fill	HS	6:37 AM	5	ND	Y	Y	Green	Initial First Draw, Filtered.
PFC-76	Classroom C105 and C103 Bathroom, Left Faucet	PB	7:53 AM	5	ND	Y	Y	7/12/2022	Initial First Draw, Filtered.
PFC-77	Classroom C105 and C103 Bathroom, Middle Faucet	PB	7:54 AM	5	3	Y	Y	7/12/2022	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



**Ann Arbor Public Schools  
Drinking Water Analysis  
Project Number: AE230030**

<b>Westerman Preschool</b>									
<b>Date of Sampling: January 6, 2023</b>									
<b>Sampler: Sabrina Fouche and Victoria Heed</b>									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
PFC-78	Classroom C105 and C103 Bathroom, Right Faucet	PB	7:55 AM	5	3	Y	Y	7/12/2022	Initial First Draw, Filtered.
PFC-79	Classroom C102 and C100 Bathroom, Left Faucet	PB	8:10 AM	5	1	Y	Y	7/12/2022	Initial First Draw, Filtered.
PFC-80	Classroom C102 and C100 Bathroom, Middle Faucet	PB	8:11 AM	5		Y	Y	7/12/2022	Initial First Draw, Filtered.
PFC-81	Classroom C102 and C100 Bathroom, Right Faucet	PB	8:12 AM	5	1	Y	Y	7/12/2022	Initial First Draw, Filtered.
PFC-82	Classroom D100 and D102 Bathroom, Left Faucet	PB	6:45 AM	5	2	Y	Y	7/12/2022	Initial First Draw, Filtered.
PFC-83	Classroom D100 and D102 Bathroom, Middle Faucet	PB	6:46 AM	5	1	Y	Y	7/12/2022	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
 Drinking Water Analysis  
 Project Number: AE230030

Westerman Preschool									
Date of Sampling: January 6, 2023									
Sampler: Sabrina Fouche and Victoria Heed									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
PFC-84	Classroom D100 and D102 Bathroom, Right Faucet	PB	6:47 AM	5	1	Y	Y	7/12/2022	Initial First Draw, Filtered.
PFC-85	Classroom D104 and D103 Bathroom, Left Faucet	PB	7:03 AM	5	3	Y	Y	7/12/2022	Initial First Draw, Filtered.
PFC-86	Classroom D104 and D103 Bathroom, Middle Faucet	PB	7:04 AM	5	3	Y	Y	7/12/2022	Initial First Draw, Filtered.
PFC-87	Classroom D104 and D103 Bathroom, Right Faucet	PB	7:05 AM	5	5	Y	Y	7/12/2022	Initial First Draw, Filtered.
PFC-88	Classroom D107 Bathroom, Left Faucet	PB	7:28 AM	5	ND	Y	Y	No Filter Date	Initial First Draw, Filtered.
PFC-89	Classroom D107 Bathroom, Right Faucet	PB	7:29 AM	5	ND	Y	Y	7/1/2021	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
 Drinking Water Analysis  
 Project Number: AE230030

Westerman Preschool									
Date of Sampling: January 6, 2023									
Sampler: Sabrina Fouche and Victoria Heed									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
PFC-93	Clinic Room E102 Bathroom, Left Sink, Glass Filler	PB	6:43 AM	5	ND	N	Y	6/30/2021	Initial First Draw, Filtered.
PFC-95	Classroom A100 and A102 Bathroom, Left Faucet	PB	7:27 AM	5	1	Y	Y	7/11/2022	Initial First Draw, Filtered.
PFC-96	Classroom A100 and A102 Bathroom, Middle Faucet	PB	7:28 AM	5	2	Y	Y	7/11/2022	Initial First Draw, Filtered.
PFC-97	Classroom A100 and A102 Bathroom, Right Faucet	PB	7:29 AM	5	2	Y	Y	7/11/2022	Initial First Draw, Filtered.
PFC-98	Classroom A103 and A105 Bathroom, Left Faucet	PB	7:08 AM	5	1	Y	Y	7/12/2022	Initial First Draw, Filtered.
PFC-99	Classroom A103 and A105 Bathroom, Middle Faucet	PB	7:09 AM	5	ND	Y	Y	7/12/2022	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
 Drinking Water Analysis  
 Project Number: AE230030

Westerman Preschool									
Date of Sampling: January 6, 2023									
Sampler: Sabrina Fouche and Victoria Heed									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
PFC-100	Classroom A103 and A105 Bathroom, Right Faucet	PB	7:10 AM	5	ND	Y	Y	7/12/2022	Initial First Draw, Filtered.
PFC-108	Classroom B100 and B102 Bathroom, Left Faucet	PB	7:46 AM	5	ND	Y	Y	7/12/2022	Initial First Draw, Filtered.
PFC-109	Classroom B100 and B102 Bathroom, Middle Faucet	PB	7:47 AM	5	ND	Y	Y	7/12/2022	Initial First Draw, Filtered.
PFC-110	Classroom B100 and B102 Bathroom, Right Faucet	PB	7:48 AM	5	ND	Y	Y	7/12/2022	Initial First Draw, Filtered.
PFC-111	Classroom B105 and B103 Bathroom, Left Faucet	PB	8:08 AM	5	ND	Y	Y	7/12/2022	Initial First Draw, Filtered.
PFC-112	Classroom B105 and B103 Bathroom, Middle Faucet	PB	8:09 AM	5	2	Y	Y	7/12/2022	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
 Drinking Water Analysis  
 Project Number: AE230030

Westerman Preschool									
Date of Sampling: January 6, 2023									
Sampler: Sabrina Fouche and Victoria Heed									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
PFC-113	Classroom B105 and B103 Bathroom, Right Faucet	PB	8:10 AM	5	2	Y	Y	7/12/2022	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L