



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Bach Elementary School							
Date of Sampling: March 5, 2022							
Sampler: Zachary Fortin							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Bach-01	Room 202, Combination Sink, Glass Filler	C	8:49 AM	5	ND ³	N	First Draw, Filtered.
Bach-03	Room A-24, Combination Sink, Glass Filler	C	7:54 AM	5	2	N	First Draw, Filtered.
Bach-06	Room A-29, Combination Sink, Glass Filler	C	7:49 AM	5	ND	N	First Draw, Filtered.
Bach-09	Room 18, Combination Sink, Glass Filler	C	8:08 AM	5	ND	N	First Draw, Filtered.
Bach-23	Room 21, Combination Sink, Glass Filler	C	8:11 AM	5	ND	N	First Draw, Filtered.
Bach-33	Auditorium, Hydration Station, Bottle Fill	HS	8:01 AM	5	ND	Y	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030

Bach Elementary School							
Date of Sampling: March 5, 2022							
Sampler: Zachary Fortin							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Bach-45	Hallway Outside Room 104, Hydration Station, Bottle Fill	HS	8:17 AM	5	ND	Y	First Draw, Filtered.
Bach-46	Hallway Outside Room 306, Hydration Station, Bottle Fill	HS	8:55 AM	5	ND	Y	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb