



**Ann Arbor Public Schools  
Drinking Water Analysis  
Project Number: AE240030**

Site: Ann Arbor STEAM at Northside									
Sampling Type: Initial First Draw Sampling (IFD)									
Date of Sampling: January 20, 2024									
Sampler: Dean Johnson									
Sample #	Location	Fixture Type	Time Collected	District Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date	Notes
STEAM - 06	Room 501, Combination Sink, Glass Filler	Combination Sink	4:18 PM	5	ND	Y	Y	N/A	
STEAM - 18	Room 102, Combination Sink, Glass Filler	Combination Sink	4:37 PM	5	ND	Y	Y	N/A	
STEAM - 37	Room 402, Combination Sink, Glass Filler	Combination Sink	4:15 PM	5	ND	Y	Y	N/A	
STEAM - 43	Kitchen 3-Compartment Sink, Add On Faucet , Far Right Faucet, Kitchen Faucet	Kitchen Faucet	4:20 PM	5	ND	Y	Y	N/A	
STEAM - 50	Room 301, Combination Sink, Glass Filler	Combination Sink	4:30 PM	5	ND	Y	Y	N/A	
STEAM - 57	Hallway, Outside MS-6, Hydration Station, Bottle Fill	Hydration Station	4:44 PM	5	ND	Y	N	N/A	
STEAM - 61	Hallway, Outside Room 200, Hydration Station, Bottle Fill	Hydration Station	4:27 PM	5	ND	Y	N	N/A	
STEAM - 65	Hallway, Outside Room 103, Hydration Station, Bubbler	Hydration Station	4:34 PM	5	ND	Y	N	N/A	
STEAM - 68	Hallway, Outside MS-1, Hydration Station, Bottle Fill	Hydration Station	4:41 PM	5	ND	Y	N	N/A	

\*ND = Non-Detected at Reported Detection Limit of 1 ug/L