

Skyline High School Sampling Results Table

Skyline High School				
Location	Parameter	Result	MCL/AL	Method Reference
Skyline-05: Main Office Suite, Room A204-D, Kitchen Sink	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
Skyline-10: Pool Deck, Single Bottle Fill	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
Skyline-24: Room A119, Athletic Training Room, Faucet in Main Room	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
Skyline-45: Kitchen, Central Island, Single Compartment Sink	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
Skyline-48: Room A303-A, Kitchen Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
Skyline-55: Room B308, Sink	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
Skyline-56: Room C303-A Kitchen Sink	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
Skyline-57: Room A403-A Kitchen Sink	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
Skyline-64: Room C403-A, Kitchen Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
	Total Residual Chlorine	0.0 PPM	N/A	N/A
Skyline-74: Outbuilding, Football Field, Concessions 3-Compartment Sink, Add on Faucet, Far Right	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035