



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE240030

Site: Scarlett Middle School									
Sampling Type: Initial First Draw Sampling (IFD)									
Date of Sampling: February 16, 2024									
Sampler: Teagan Evans									
Sample #	Location	Fixture Type	Time Collected	District Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date	Notes
Scarlett-33	Hallway, Outside Room 130, Hydration Station, Bottle Fill	Hydration Station	10:21 AM	5	ND	Y	N	N/A	
Scarlett-34	Mail Room #A111, Combination Sink, Glass Filler	Combination Sink	10:27 AM	5	ND	N	N	N/A	
Scarlett-09	Staff Kitchen Faucet in Cafeteria	Kitchen Faucet	10:45 AM	5	ND	Y	N	N/A	
Scarlett-10	Hallway, Outside Main Office by Stairway, Single Glass Filler	Single Bottle Fill	10:50 AM	5	ND	N	N	N/A	
Scarlett-16	Hallway, Outside Room 215, Hydration Station, Bottle Fill	Hydration Station	11:00 AM	5	ND	Y	N	N/A	
Scarlett-29	Hallway, Outside of Gym, Hydration Station, Bottle Fill	Hydration Station	11:17 AM	5	ND	Y	N	N/A	
Scarlett-31	Hallway, Outside Room 205, Single Glass Filler	Single Bottle Fill	11:08 AM	5	ND	N	N	N/A	
Scarlett-35	Auxiliary Gym, Hydration Station, Bottle Fill	Hydration Station	11:29 AM	5	ND	Y	N	N/A	

*ND = Non-Detected at Reported Detection Limit of 1 ug/L